



# SKEP III Home Office Support Site Visit Report

**WAHIB  
MEDANAT**  
consultant engineers

Consultant	Wahib Medanat Consultant Engineer	Rep No.	21-03062021
Contractor	Dijlah Establishment Constr. Contracting	Tender No.	(11/2019/USAID/SKEP/3/S) Schools for a Knowledge Economy Project (SKEP) - Phase (3) Package (1, 2)
Site Name	Hay Al Iskan Basic Mixed School- Jerash	Day/ Date	Sat. 03/06/2021
Duration of Project	450 Calendar Days	Total Project Budget	8,314,983.735 JD

No.	Visitors		Remarks
1	Suhair Amarin	- Project Dir./Head of Architectural Department	
2	Omar Elayan	-Senior Civil Engineer	
3	Akram Khammes	- Head of Electrical Department	
4	Marwan Sonna'a	-Head of Mechanical Department	
5	Hasan Shaqboua	-Quality Control Manager	

## Visit Notes

No.	Description
1	- Blockwork: The quality is acceptable in general. Narrow spaces between block wall and ceiling were filled with saw cut blocks.
2	- Discussion with the Contractor as follows: <ul style="list-style-type: none"> <li>Aluminum work: issue of the accessories was discussed in accordance to the contract requirements to be stainless steel accessories. The Contractor stated that only one of the three sources in the Vendor List can supply those accessories. The Contractor presented a catalogue where the pin of the hinge only is stainless steel not all the accessory. The contractor was requested to comply with the specifications which indicates that the whole accessories shall be stainless steel.</li> <li>Mechanical submittals were discussed.</li> </ul>



Project  
ID Sign  
on Site





Temperature check, sterilization and signing visitors' attendance sheet at the entrance of the site, complying with Covid-19 Protocol





Shot  
shows  
perfect  
finish for  
window  
jamb





WAHIB  
MED  
consulting



The narrow spaces between block wall and the ceiling is filled with saw cut block



First stage of plastering work



WAHIB  
MEDANAT  
consultant



Steel  
Reinforcement  
of part B of the  
First floor slab  
and curing  
works for the  
casted part A





WAHIB  
MEDANAT  
consultant engineers



Aluminum work issue and Mechanical submittals were discussed with the Contractor



Tour inside the site was conducted