



SKEP III Home Office Support Site Visit Report

**WAHIB
MEDANAT**
consultant engineers

Consultant	Wahib Medanat Consultant Engineer	Rep No.	22-17072021
Contractor	Dijlah Establishment Constr. Contracting	Tender No.	(11/2019/USAID/SKEP/3/S) Schools for a Knowledge Economy Project (SKEP) - Phase (3) Package (1, 2)
Site Name	Thahr Al Sarow Basic School for Boys- Jerash	Day/ Date	Sat. 17/07/2021
Duration of Project	450 Calendar Days	Total Project Budget	8,314,983.735 JD

No.	Visitors		Remarks
1	Suhair Amarin	- Project Dir./Head of Architectural Department	
2	Omar Elayan	-Senior Civil Engineer	
3	Akram Khammes	- Head of Electrical Department	
4	Marwan Sonna'a	-Head of Mechanical Department	
5	Hasan Shaqboua	-Quality Control Manager	

Visit Notes

No.	Description
1	- Radiators: Execution of first fix (Bottom-Top) without approval.
2	- Plastering: Guidance points not to be at the opening edges.
3	- Stone: The same chiseling pattern should be done in accordance to the approved pattern by the Engineer. Stones having different pattern should be removed. It is preferable to clean the mortar at the stone face at once and further taking care to avoid such status. - Broken stones should be replaced and gaps between stone layers should be regular.



Project ID
Sign on Site





Temperature check, sterilization and signing visitors' attendance sheet at the entrance of the site, complying with Covid-19 Protocol



General view of the main building



A tour inside the site was conducted



Acceptable process and quality for plastering work



Checking quality of stonework



The Contractor is using a special container for mortar mixing used for plastering



Radiators:
Execution of
first fix
(Bottom-Top)
without
approval





An example of the concrete jamb for windows as required